

**GOVERNMENT OF TELANGANA,
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

From:

**Sri. K. Madhusudana Rao, B.Sc., B.Ed.,
Ad.D.F.E.(NFSC) D.L.S.**

**District Fire Officer,
Nizamabad,**

Sir,

To,

**The District Educational Officer,
Kamareddy District.**

Rc. No. 1125/B5/2021 Dated. 25-09-2021

Sub:- Telangana State Disaster Response and Fire Services Department - C/S-
Nizamabad District - Issue of No Objection Certificate for Occupancy to the
Existing Educational Building of **Frobels High School**, Situated at
Adloor Road Kamareddy - Regarding.

- Ref:-1)** Section 13 (2) of Andhra Pradesh Fire Services Act, 1999 and Rule 15 (2)
of A.P. Fire and Emergency operations and Levy of Fee Rules, 2006.
- 2)** Chief Office Circular Memo.Rc.No.2305/B2/2007 Dt. 28-02-2007, 12-09-2008
and 22-10-2013.
- 3)** G.O. Ms. No. 154, Municipal Administration & urban Development
Department Dt.13-03-2007.
- 4)** Cr.Memo.Rc No.15009/MSB/CR/HYD/2012 Dt. 06-11-2013 of the Director
General State Disaster Response and Fire Services, Andhra Pradesh,
Hyderabad.
- 5)** Application Dt.01-06-2021 of Secretary/Correspondent, **Frobels High
School**, Adloor Road Kamareddy District.
- 6)** Inspection committee Report Rc.No.III/ADFO/NZE/2021 Dt.20-07-2021

Vide reference 5th cited, the Secretary/Correspondent, **Frobels High School**,
Adloor Road Kamareddy District has requested for the issue of No Objection Certificate
for Occupancy to the existing educational Building of **Frobels High School**,
Situated at **Adloor Road Kamareddy District**

ii) Vide reference 6th cited, the inspection committee have inspected the building
on 21-07-2016 and recommended for the issue of No Objection Certificate for Occupancy
for the above Educational Building.

a) Particulars of the Educational Building:-

- 1) Address of the Building :- **Frobels High School**, Situated at **Adloor
Road Kamareddy**
- 2) Plot area :- **8317.00 Sq. Mtrs**
- 3) No of floors :- **Ground + 02 Upper floors only.**
- 4) Height of the Building :- **09.75 Mtrs.**

iii) Open Spaces :-

Direction	Required as per NBC	Provided	Remarks
North	06.00 Mtrs.	02.00 Mtrs.	The open spaces are not mandatory for the Existing buildings Height Below 15 Mtrs. Or less than 500 Sq Mtrs. area As per G.O.Ms.No. 154 Municipal Admin. And urban Development (H1) Department Dt. 13-03-2007
South	06.00 Mtrs.	NIL	
East	06.00 Mtrs.	NIL	
West	06.00 Mtrs.	NIL	

P.T.O

**PRINCIPAL
FROBELS HIGH SCHOOL
KAMAREDDY**

**Secretary & Correspondent
FROBELS HIGH SCHOOL
Kamareddy-503111**

iv) Floor wise particulars:-

:2::

SL No	Floor	Floor area in Sq. Meters	Occupancy	No. of Students & Staff members in the Floor
1	Ground Floor	2772.00 Sq.Mtrs.	Educational	320
2	1 st Floor	2772.00 Sq.Mtrs.	Educational	320
3	2 nd Floor	2772.00 Sq.Mtrs.	Educational	320
	Total	8316.00 Sq.Mtrs.		

v) Means of Escape (a):

SL No.	Details of Staircases	Required		Provided		Total
		No. 5	Width	No.	Width	
1	Internal Staircases	01	01.50 Mtrs.	01	01.00 Mtrs.	01.00 Mtrs.
2	External Staircases
	Total			01	01.00 Mtrs.	01.00 Mtrs.

Highest No. of Students in a Floor	Width of Staircases required (No. of Students divided by 50 = _____ Meters)	Aggregate width of Staircases provided	Deficit
44	44/25 = 1.76 units or 0.88 Mtrs.	01.00 Mtrs.	NIL

vi) The management has remitted Fire precaution fee for Rs.10,000/-Vide Challans 6102278943 Dt. 25-05-2021 at S.B.H, Kamareddy

viii) Fire Safety Measures:

SL No	Fire Safety Measures	Required as per Table 23 of NBC of India 2005	Provided	Deficiency
1	Fire Extinguishers	1) 02 No.s D.C.P Fire Extinguisher. 2) 01 No.s Co ₂ Fire Extinguisher. 3) 04 No.s 9 Ltrs. Round bottom Fire buckets (Two filled with water & Two filled with dry sand)	Yes, Provided	NIL

ix) The Fire Safety systems were tested by the committee members during the inspection and performance found satisfactory. Therefore, this Office has No Objection for Occupancy clearance to the existing Educational Building of Frobels High School, Situated at Adloor Road, Kamareddy District Subject to the following Conditions

i	All the Fire protection arrangements shall be maintained in good working Condition as seen during inspection.
ii	All the escape/exit routes shall not be kept locked/ blocked or encroached.
iii	All the occupants must know the correct method of operation of the Fire Fighting system installed.
iv	Any loss of life or property due to non - functioning of Fire safety measures and other installations shall be the responsibility of the management.
v	All students/staff members of the institution shall be trained to operate the Fire safety equipments during emergency.
vi	Addition /alteration, if any in the building may be obtained with prior permission from this Department
vii	Mock Drills should be conducted once in 3 months for initial two years. Thereafter, once in every 06 Months.
viii	All live electrical wires shall be removed from site.

This No objection Certificate for Occupancy is valid for a period of one year from the date of issue. The management should apply for renewal of No Objection Certificate before two months from the date of expiry.

Yours faithfully,

[Signature]
District Fire Officer,
Nizamabad

Copy to the Station Fire Officer, Kamareddy.

Copy to Asst. District Fire Officer, Nizamabad.

Copy to the Secretary/Correspondent, Frobels High School
Adloor Road, Kamareddy District

[Signature]
PRINCIPAL
FROBELS HIGH SCHOOL
KAMAREDDY

[Signature]
Secretary & Correspondent
FROBELS HIGH SCHOOL
Kamareddy-503111